# DRINKING WATER NOTICE

## Buckeye Water District – Ohio River PWS

**Significant Deficiency/Treatment Technique Requirements**

The Ohio EPA has identified, through the sanitary survey conducted on June 25 and June 28, 2024, significant deficiencies associated with the public water system. The Buckeye Water District – Ohio River PWS failed to take adequate corrective action to timely address deficiencies with its finished water storage tanks and failed to implement a backflow prevention program consistent with the requirements of Chapter 3745-95 of the Ohio Administrative Code.
At the present time, the Buckeye Water District has implemented a schedule to address the deficiencies of its finished water storage tanks and has instituted a backflow prevention program which will commence in the month of April. The recent implementation of the infrastructure fee will provide the necessary resources to facilitate this corrective action plan.
***Buckeye Water District remains in compliance with the water quality standards set forth in the Safe Drinking Water Act ***

**What should I do?**

- There is nothing for you to do at this time.

**What does this mean?**

- This situation does not require that you take immediate action. If it had been, you would have been notified immediately.

**What happened? What is being done?**

- We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact John Gentile at 330-532-1247 or 1925 Clark Ave.

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1-800-426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWS ID#: OH1502911 Date distributed: 4-2025